



HAZARDOUS MATERIAL SPILLS INFORMATION REQUEST

EXXON

5400 SUNRISE HIGHWAY

MASSAPEQUA, NY NO ZIP PROVIDED

Spill Number: 8605634

Close Date:

ADDRESS CHANGE INFORMATION

Revised street: NO CHANGE

Revised zip code: 11758

Source of Spill: GASOLINE STATION OR PBS FACILITY

Spiller: EXXON

Spiller Phone:

Notifier Type: Tank Tester

Notifier Name:

Notifier Phone:

Caller Name:

Caller Agency:

Caller Phone:

DEC Investigator: RDDECAND

Contact for more spill info:

Contact Person Phone:

Category: Known or probable release, where, without action, there is a potential for a fire/explosion hazard (indoors or outdoors), contamination of drinking water supplies, or significant release to surface waters.

Class: Willing RP – No DEC Field Response – Corrective Action Initiated or Completed by RP or Other Agency

Spill Date	Date Cleanup Ceased	Cause of Spill	Meets Cleanup Standards		Penalty Recommended	
11/07/1986		EQUIPMENT FAILURE	NO		NO	

Material Spilled	Material Class	Quantity Spilled	Units	Quantity Recovered	Units	Resource(s) Affected
GASOLINE	PETROLEUM	0.00	GALLONS	0.00	GALLONS	GROUNDWATER
MTBE (METHYL-TERT-BUTYL ETHER)	HAZARDOUS MATERIAL	0.00	UNKNOWN	0.00	UNKNOWN	GROUNDWATER

Caller Remarks:

PIPELINE FAILED PETROTITE LINE TEST -.037

DEC Investigator Remarks:

Prior to Sept, 2004 data translation this spill Lead_DEC Field was DECANDIA WELL

// : SITE WELLS TO BE REQUESTED. 8/21/00 FILE REASSIGNED

6/17/04 FILE REASSIGNED

NYSDEC FALL 1998 MTBE SURVEY INFORMATION FOR 8605634

Maximum MTBE concentration: 270000.0 PPB

Current MTBE concentration: 2600.0 PPB

BTEX offsite: Yes

Source of MTBE		Number of private drinking water wells impacted: 0
		Number of public water supply wells impacted: 0
Steel Underground Storage Tank -		Number of private drinking water wells impacted: 0
Fiberglass Underground Tank -		Number of replacement wells drilled: 0
Aboveground Storage Tank -		Number of water main extensions: 0
Piping -		Number of water main hookups: 0
Source not identified - X		Number of residences provided w/ bottled water: 0
Other source -		Number of people affected: 0

Indoor Air Impacts : No
Aquifer Impacts : Yes

Ongoing remediation: Yes

Monitoring Frequency
Monthly - Quarterly - Semi-annual - Annual - Other -

Remedial Action used
No Action -

Groundwater		Soil	
Pump and Treat -		Soil Vapor extraction	-
Air sparging -		Excavation and disposal	- X
Bioreactor -		Bioremediation	-
Natural attenuation -		Low temp thermal desorption	-
Oxygen injection - X		Oxygen injection	- X
Biosparging -		Other	-
Dual phase extraction -			
Other -			

Under investigation: Yes
Dept. of Health involvement: No

Dept. of Health Remarks: No remarks given for this spill

General Remarks: No remarks given for this spill