



HAZARDOUS MATERIAL SPILLS INFORMATION REQUEST

EXXON SERVICE STATION

660 ISLIP AVENUE

BRENTWOOD, NY NO ZIP PROVIDED

Spill Number: 9409268

Close Date:

ADDRESS CHANGE INFORMATION

Revised street: NO CHANGE

Revised zip code: 11717

Source of Spill: GASOLINE STATION OR PBS FACILITY

Spiller: EXXON SERVICE STATION

Spiller Phone: (516) 876-4660

Notifier Type: Other

Notifier Name:

Notifier Phone:

Caller Name: ROBERT APPLEBAUM

Caller Agency: UNICO

Caller Phone: (516) 864-1772

DEC Investigator: RDDECAND

Contact for more spill info:

Contact Person Phone:

Category: Known petroleum or hazardous material release with minimal potential for fire/explosion (indoors or outdoors), drinking water contamination, or releases to surface waters.

Class: Willing RP – DEC Field Response – Corrective Action Initiated, Taken Over, or Completed by RP or Other Agency

Spill Date	Date Cleanup Ceased	Cause of Spill	Meets Cleanup Standards	Penalty Recommended
07/22/1994		OTHER	NO	NO

Material Spilled	Material Class	Quantity Spilled	Units	Quantity Recovered	Units	Resource(s) Affected
GASOLINE	PETROLEUM	0.00	GALLONS	0.00	GALLONS	SOIL
MTBE (METHYL-TERT-BUTYL ETHER)	HAZARDOUS MATERIAL	0.00	UNKNOWN	0.00	UNKNOWN	

Caller Remarks:

INSTALLING SOIL BORINGS DETECTED HIGH LEVEL OF HYDROCARBONS, TESTED SOIL WAS FOUND TO BE ABOVE STATE GUIDELINES, REPORT DELIVERED TO EXXON

DEC Investigator Remarks:

Prior to Sept, 2004 data translation this spill Lead_DEC Field was DECANDIA WELL 8/21/00 FILE REASSIGNED

6/17/04 FILE REASSIGNED

10/21/04 address changed to 660 Islip Avenue....

NYSDEC FALL 1998 MTBE SURVEY INFORMATION FOR 9409268

Maximum MTBE concentration: 32000.0 PPB
BTEX offsite: Yes

Current MTBE concentration: 25000.0 PPB

Source of MTBE

Steel Underground Storage Tank - X
Fiberglass Underground Tank -
Aboveground Storage Tank -
Piping -
Source not identified -
Other source -

Number of private drinking water wells impacted: 0
Number of public water supply wells impacted: 0
Number of private drinking water wells impacted: 0
Number of replacement wells drilled: 0
Number of water main extensions: 0
Number of water main hookups: 0
Number of residences provided w/ bottled water: 0
Number of people affected: 0

Indoor Air Impacts : No
Aquifer Impacts : Yes

Ongoing remediation: Yes

Monitoring Frequency

Monthly - Quarterly - X Semi-annual - Annual - Other -

Remedial Action used

No Action -

Groundwater

Pump and Treat -
Air sparging - X
Bioreactor -
Natural attenuation -
Oxygen injection -
Biosparging -
Dual phase extraction -
Other -

Soil

Soil Vapor extraction - X
Excavation and disposal - X
Bioremediation -
Low temp thermal desorption -
Oxygen injection -
Other -

Under investigation: No

Dept. of Health involvement: No

Dept. of Health Remarks: No remarks given for this spill

General Remarks: Remediation equipment is on order.