



**HAZARDOUS MATERIAL SPILLS INFORMATION REQUEST**

**EXXON S/S**

340 ROCKAWAY TPKE

CEDARHURST, NY NO ZIP PROVIDED

**Spill Number: 9311501**

**Close Date:**

ADDRESS CHANGE INFORMATION

Revised street: NO CHANGE

Revised zip code: 11516

Source of Spill: GASOLINE STATION OR PBS FACILITY

Spiller: EXXON S/S

Spiller Phone:

Notifier Type: DEC

Notifier Name:

Notifier Phone:

Caller Name: KAREN GOMEZ

Caller Agency: DEC

Caller Phone: (516) 444-0320

DEC Investigator: rddecand

Contact for more spill info:

Contact Person Phone:

Category: Known or probable release, where, without action, there is a potential for a fire/explosion hazard (indoors or outdoors), contamination of drinking water supplies, or significant release to surface waters.

Class: Willing RP – DEC Field Response – Corrective Action Initiated, Taken Over, or Completed by RP or Other Agency

Spill Date	Date Cleanup Ceased	Cause of Spill	Meets Cleanup Standards	Penalty Recommended
12/15/1993		UNKNOWN	NO	NO

Material Spilled	Material Class	Quantity Spilled	Units	Quantity Recovered	Units	Resource(s) Affected
GASOLINE	PETROLEUM	0.00	GALLONS	0.00	GALLONS	GROUNDWATER
MTBE (METHYL-TERT-BUTYL ETHER)	HAZARDOUS MATERIAL	0.00	UNKNOWN	0.00	UNKNOWN	GROUNDWATER

Caller Remarks:

MONITORING OF SITE WELLS BEING DONE BY MEG FOR 8000022, STATE FUNDED PROJECT, **PRODUCT DISCOVERED IN WELLS** AROUND TANK BED AFTER SEVERAL YEARS OF NO PRODUCT, **PRODUCT THICKNESS CONTINUED TO INCREASE**

DEC Investigator Remarks:

Prior to Sept, 2004 data translation this spill Lead\_DEC Field was DECANDIA WELL 8/21/00 FILE REASSIGNED

6/17/04 FILE REASSIGNED

**NYSDEC FALL 1998 MTBE SURVEY** INFORMATION FOR 9311501

Maximum MTBE concentration: 320000.0 PPB

Current MTBE concentration: **320000.0 PPB**

BTEX offsite: No

Source of MTBE		Number of private drinking water wells impacted: 0
		Number of public water supply wells impacted: 0
Steel Underground Storage Tank	-	Number of private drinking water wells impacted: 0
Fiberglass Underground Tank	-	Number of replacement wells drilled: 0
Aboveground Storage Tank	-	Number of water main extensions: 0
Piping	- X	Number of water main hookups: 0
Source not identified	- X	Number of residences provided w/ bottled water: 0
Other source	-	Number of people affected: 0

Indoor Air Impacts : No  
Aquifer Impacts : Yes

Ongoing remediation: Yes

Monitoring Frequency  
Monthly -                      Quarterly - X                      Semi-annual -                      Annual -                      Other -

Remedial Action used  
No Action -

Groundwater		Soil	
Pump and Treat	-	Soil Vapor extraction	- X
Air sparging	- X	Excavation and disposal	-
Bioreactor	-	Bioremediation	-
Natural attenuation	-	Low temp thermal desorption	-
Oxygen injection	-	Oxygen injection	-
Biosparging	-	Other	-
Dual phase extraction	-		
Other	-		

Under investigation: No  
Dept. of Health involvement: No

-----  
Dept. of Health Remarks: No remarks given for this spill  
-----

General Remarks: No remarks given for this spill